


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE No. 89/DJS/DLWQTML/2026-27

Date : 13/08/2026

It is certified that an inspection team headed by Er. Pawan singh ,Technical Manager from DLWQTML uttarakhand jal sansthan champawat inspected the Indus National School, Ladwal Estate g G.G.T.C Road Champawat on 13/08/2026 and found that the Indus National School, Ladwal Estate G.G.T.C Road Champawat has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1.



Signature with Seal :

सहायक अभियन्ता
उत्तराखण्ड जल संस्थान
चम्पावत

Designation : Technical manager

To

PRINCIPAL
INDUS NATIONAL SCHOOL
CHAMPAWAT

Principal

Indus National School
Ladwal Estate G.G.T.C Road
Champawat

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 89/UTS/DLWQTML/2026-2027

Dated: 13/08/2026

It is certified that an inspection team headed by

Er. Pawan Singh, Technical Manager (Name of Officers with designation)

from Uttarakhand Jal Sansthan, Champawat PHED

inspected the Indus National School, Champawat

(Name & Address of the school) on 12/08/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 89/UTS/DLWQTML/2026-2027

dated 12/08/2026 of District Level Water Quality (PHED Lab)

certified that the Testing and Monitoring Laboratory Uttarakhand Jal Sansthan, Champawat

Indus National School, Champawat (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 13.08.2027

Signature with Seal: [Signature]

Name : सहायक अभियन्ता

Designation : उत्तराखण्ड जल संस्थान

Name & Address of the Office / Department : चम्पावत

To Principal
Indus National School
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Level Water Quality Testing and Monitoring Laboratory Uttarakhand Jal Sansthan, Champawat

Ph (O): 05965-230485 E-mail: eechp-ujs-uk@nic.in



NABL T0726UK18773

TEST REPORT

Name and Address of Organization/Customer	Indus National School Ladwal Estate G.G.I.C Road Champawat, Mob-9811498817		
Test Report ID	89/UJS/DLWQTML/2026-2027	Reporting Date	13/08/2026
		Sample Location	One Drinking Water Sample Submitted from Indus National School Ladwal Estate ggic road champawat (Tap Water)
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026/47		
Date of Start of Analysis:	12/08/2026		
Date of End of Analysis:	13/08/2026		
Date and Time of Sample Received:	12/08/2026, 12:35 PM		

SN	Parameters	Test Method	Result	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
----	------------	-------------	--------	---	--

(A) Organoleptic and Physical Parameters

1.	pH at 25°C	IS 3025 (Part 11)	7.46	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16)	70.00	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10)	1.24	1 Max	5 Max
4.	Colour, CU	IS 3025 (Part 4)	1	5 Max	15 Max
5.	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable

(B) General Parameters Concerning Substances

6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23)	28.00	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21)	40.00	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40)	7.20	75 Max	200 Max
9.	Chloride as Cl, mg/L	IS 3025 (Part 32)	4.50	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed-3500-Mg Method B: 2023 (Calculation Method)	5.34	30 Max	100 Max

Note:-1. The results listed refer only to tested sample and applicable parameters

2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.

3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.

4. The results apply to the sample as received

5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

[Signature]
Tested by
(Chemist)

[Signature]
Review by
(Chemist)

[Signature]
Authorized by
(Technical Manager)
सहायक अभियन्ता
उत्तराखण्ड जल संस्थान
चम्पावत



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Champawat

Ph (O): 05965-230485 E-mail: eechnp-ujs-uk@nic.in

TEST REPORT

Name and Address of Organization/ Customer	Indus National School Ladwal Estate G.G.I.C Road Champawat, Mob-9811498817		
Test Report ID	89A/UJS/DLWQTML/2026-2027	Reporting Date	13/08/2026
		Sample Location	One Drinking Water Sample Submitted from Indus National School Ladwal Estate ggic road champawat (Tap Water)
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026/47		
Date of Start of Analysis:	12/08/2026		
Date of End of Analysis:	13/08/2026		
Date and Time of Sample Received:	12/08/2026, 12:35 PM		

S.N	Parameters	Test Method	Results	Shall Not be Detected in 100ml	Shall Not be Detected in 100ml
1.	Total Coliform, 100ml	IS 15185:2016	Absent	Absent	Absent
2.	E. coli, 100ml	IS 15185:2016	Absent	Absent	Absent

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

Path
Tested by
(Chemist)

Tamje
Review by
(Chemist)

Path
Authorized by
सह (Deputy Manager)
उत्तराखण्ड जल संस्थान
चम्पावत