

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 76/UIS/DLWQ/TML/2025-26

Dated: 19/08/2025

It is certified that an inspection team headed by Er. Pawan Singh Assistant Engineer
(Name of Officers with designation) from Uttarakhand Jal Samsthan Champawat
(Name of Department/ Office) inspected the Indus National School Champawat
(Name & Address of the school) on 18/08/2025 (date of inspection) and found that the
Indus National School (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To

Principal
Indus National School

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



District Level Water Quality Testing and Monitoring Laboratory Uttarakhand Jal Sansthan, Champawat



TC-13417

TEST REPORT

Name and Address of Organization/ Customer	Indus National School, Champawat		
Test Report ID	176/UJS/DLWQTML/2025-2026	Reporting Date	19/08/2025
		Sample Location	One Drinking Water Sample Submitted from Indus National School (Tap Water) Ladwal state G.G.I.C Road Champawat
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/INS-01		
Date of Start of Analysis:	18/08/2025		
Date of End of Analysis:	19/08/2025		
Date and Time of Sample Received:	18/08/2025, 12:20PM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022,	7.64	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	78.00	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	1.12	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	58.00	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	72.00	200	600
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	18.60	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	4.54	250	1000
8.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	6.80	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	5	5	15
10	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

- Note: 1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

****End of Report****

Indu
Reviewed and Authorized By
Dr. Indu Singh
Technical Manager, Lab
Uttarakhand Jal Sansthan
Champawat



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Champawat

TEST REPORT

Name and Address of Organization/ Customer	Indus National School, Champawat		
Test Report ID	176A/UJS/DLWQTML/2025-2026	Reporting Date	19/08/2025
		Sample Location	One Drinking Water Sample Submitted from Indus National School (Tap Water) Ladwal state G.G.I.C Road Champawat
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/INS-01		
Date of Start of Analysis:	18/08/2025		
Date of End of Analysis:	19/08/2025		
Date and Time of Sample Received:	18/08/2025, 12:20PM		

SN	Parameters	Test Method	Results	Shall Not be Detected in 100ml	Shall Not be Detected in 100ml
1.	Total Coliform, 100ml	IS 15185:2016	Absent	Absent	Absent
2.	<i>E. coli</i> , 100ml	IS 15185:2016	Absent	Absent	Absent

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****


Review and Authorized By
Er. Pawan Singh
Technical Manager, Lab
Uttarakhand Jal Sansthan
Champawat